



**Office of Environmental Health &  
Safety**

**Facility Inspection Program**

333 S. Beaudry Avenue

Los Angeles, CA 90017

Phone: (213) 241-3199

Fax: (213) 241-6816



## Drinking Water Sampling Results for Lead

**School Name:** Normandie Avenue  
Elementary School

**Address:** 4505 South  
Raymond Avenue  
Los Angeles, CA  
90037

**Sample Date:** 11/19/2008

<b>Draw Type</b>	<b>Location Description</b>	<b>Equipment Number</b>	<b>Concentration (Parts Per Billion)</b>
First Draw	Sink, 3 BUB. (INT.) - Caf� Bldg Kit N. Wall -- BUBBLER1, FCT - Caf� Bldg Kit N. Wall	188455-40048	17 ppb
30 Second Draw	Sink, 3 BUB. (INT.) - Caf� Bldg Kit N. Wall -- BUBBLER1, FCT - Caf� Bldg Kit N. Wall	188455-40048	<5 ppb
First Draw	Sink, 3 BUB. (INT.) - Caf� Bldg Kit N. Wall -- BUBBLER2, FCT - Caf� Bldg Kit N. Wall	188455-41224	6.6 ppb
30 Second Draw	Sink, 3 BUB. (INT.) - Caf� Bldg Kit N. Wall -- BUBBLER2, FCT - Caf� Bldg Kit N. Wall	188455-41224	<5 ppb
First Draw	Sink, 3 BUB. (INT.) - Caf� Bldg Kit N. Wall -- BUBBLER3, FCT - Caf� Bldg Kit N. Wall	188455-41526	<5 ppb
30 Second Draw	Sink, 3 BUB. (INT.) - Caf� Bldg Kit N. Wall -- BUBBLER3, FCT - Caf� Bldg Kit N. Wall	188455-41526	<5 ppb
First Draw	Other, 1 BUB. (INT.) - Caf� Bldg Kit S. Wall -- BUBBLER1, PF - Caf� Bldg Kit S. Wall	188459-40049	17000 ppb
30 Second Draw	Other, 1 BUB. (INT.) - Caf� Bldg Kit S. Wall -- BUBBLER1, PF - Caf� Bldg Kit S. Wall	188459-40049	64 ppb
First Draw	Sink, 1 BUB. (INT.) - Caf� Bldg Fac lounge sink -- BUBBLER1, FCT - Caf� Bldg Fac lounge sink	188461-40050	5.8 ppb
30 Second Draw	Sink, 1 BUB. (INT.) - Caf� Bldg Fac lounge sink -- BUBBLER1, FCT - Caf� Bldg Fac lounge sink	188461-40050	<5 ppb
First Draw	Sink, 1 BUB. (INT.) - Main Ofc bldg Nurse Ofc. -- BUBBLER1, FCT - Main Ofc bldg Nurse Ofc.	188463-40051	5.4 ppb
30 Second Draw	Sink, 1 BUB. (INT.) - Main Ofc bldg Nurse Ofc. -- BUBBLER1, FCT - Main Ofc bldg Nurse Ofc.	188463-40051	<5 ppb
First Draw	Sink, 1 BUB. (INT.) - Main Ofc Bldg Nurses Room -- BUBBLER1, FCT - Main Ofc Bldg Nurses Room	188465-40052	<5 ppb
30 Second Draw	Sink, 1 BUB. (INT.) - Main Ofc Bldg Nurses Room -- BUBBLER1, FCT - Main Ofc Bldg Nurses Room	188465-40052	<5 ppb
First Draw	Sink, 1 BUB. (INT.) - Main Ofc Bldg Equip Room -- BUBBLER1, FCT - Main Ofc Bldg Equip Room	188467-40053	7.5 ppb
30 Second Draw	Sink, 1 BUB. (INT.) - Main Ofc Bldg Equip Room -- BUBBLER1, FCT - Main Ofc Bldg Equip Room	188467-40053	<5 ppb
First Draw	Sink, 1 BUB. (INT.) - South Bldg Library -- BUBBLER1, FCT - South Bldg Library	188474-40054	<5 ppb
30 Second Draw	Sink, 1 BUB. (INT.) - South Bldg Library -- BUBBLER1, FCT - South Bldg Library	188474-40054	11 ppb

First Draw	Sink, 2 BUB. (INT.) - Bldg 2 Rm #61 -- BUBBLER1, R- Bldg 2 Rm #61	188523-40055	9.3 ppb
30 Second Draw	Sink, 2 BUB. (INT.) - Bldg 2 Rm #61 -- BUBBLER1, R- Bldg 2 Rm #61	188523-40055	<5 ppb
First Draw	Sink, 2 BUB. (INT.) - Bldg 2 Rm #61 -- BUBBLER2, FCT - Bldg 2 Rm #61	188523-41225	<5 ppb
30 Second Draw	Sink, 2 BUB. (INT.) - Bldg 2 Rm #61 -- BUBBLER2, FCT - Bldg 2 Rm #61	188523-41225	<5 ppb
First Draw	Sink, 1 BUB. (INT.) - Bungalow west of playground -- BUBBLER1, FCT - Bungalow west of playground	188532-40056	<5 ppb
30 Second Draw	Sink, 1 BUB. (INT.) - Bungalow west of playground -- BUBBLER1, FCT - Bungalow west of playground	188532-40056	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - E WALL OF RM K1 -- BUBBLER1, C-E WALL OF RM K1	192410-16937	8.6 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - E WALL OF RM K1 -- BUBBLER1, C-E WALL OF RM K1	192410-16937	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - E WALL OF RM K1 -- BUBBLER2, FCT - KINDERGARTEN BLDG ROOM K1	192410-41226	9.7 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - E WALL OF RM K1 -- BUBBLER2, FCT - KINDERGARTEN BLDG ROOM K1	192410-41226	<5 ppb
First Draw	DRINKING FOUNTAIN, 1 BUB. (EXT.) - N EXT WALL BTWN K1 & K2 -- BUBBLER1, C-N EXTERIOR WALL BTWN K1 &	192412-16938	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 1 BUB. (EXT.) - N EXT WALL BTWN K1 & K2 -- BUBBLER1, C-N EXTERIOR WALL BTWN K1 &	192412-16938	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM K2 -- BUBBLER1, C-NW WALL OF RM K2	192414-16939	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM K2 -- BUBBLER1, C-NW WALL OF RM K2	192414-16939	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM K2 -- BUBBLER2, FCT - KINDERGARTEN BLDG RM K-2	192414-41227	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM K2 -- BUBBLER2, FCT - KINDERGARTEN BLDG RM K-2	192414-41227	<5 ppb

First Draw	SINK, 1 BUB. (EXT.) - N EXTERIOR WALL BTWN K2 & K3 -- BUBBLER1, C-N EXTERIOR WALL BTWN K2 & K3	192416-16940	5.2 ppb
30 Second Draw	SINK, 1 BUB. (EXT.) - N EXTERIOR WALL BTWN K2 & K3 -- BUBBLER1, C-N EXTERIOR WALL BTWN K2 & K3	192416-16940	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM K3 -- BUBBLER1, C-NE WALL OF RM K3	192418-16941	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM K3 -- BUBBLER1, C-NE WALL OF RM K3	192418-16941	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM K3 -- BUBBLER2, FCT - KINDERGARTEN BLDG RM K-3	192418-41228	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM K3 -- BUBBLER2, FCT - KINDERGARTEN BLDG RM K-3	192418-41228	<5 ppb
First Draw	DRINKING FOUNTAIN, 1 BUB. (EXT.) - NE SIDE OF BLDG EXTERIOR -- BUBBLER1, C-NE SIDE OF BLDG EXTERIOR	192420-16942	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 1 BUB. (EXT.) - NE SIDE OF BLDG EXTERIOR -- BUBBLER1, C-NE SIDE OF BLDG EXTERIOR	192420-16942	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW SIDE OF BLDG EXTERIOR -- BUBBLER1, L-NW SIDE OF BLDG EXTERIOR	192422-16943	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW SIDE OF BLDG EXTERIOR -- BUBBLER1, L-NW SIDE OF BLDG EXTERIOR	192422-16943	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW SIDE OF BLDG EXTERIOR -- BUBBLER2, R-NW SIDE OF BLDG EXTERIOR	192422-16944	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW SIDE OF BLDG EXTERIOR -- BUBBLER2, R-NW SIDE OF BLDG EXTERIOR	192422-16944	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW WALL OF BLDG -- BUBBLER1, L-NW WALL OF BLDG	192425-16945	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW WALL OF BLDG -- BUBBLER1, L-NW WALL OF BLDG	192425-16945	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW WALL OF BLDG -- BUBBLER2, R-NW WALL OF BLDG	192425-16946	<5 ppb

30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NW WALL OF BLDG -- BUBBLER2, R-NW WALL OF BLDG	192425-16946	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 11 -- BUBBLER1, C-NORTHEAT WALL OF RM 11	192428-16947	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 11 -- BUBBLER1, C-NORTHEAT WALL OF RM 11	192428-16947	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 11 -- BUBBLER2, FCT - South Bldg Room #11	192428-41229	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 11 -- BUBBLER2, FCT - South Bldg Room #11	192428-41229	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 12 -- BUBBLER1, C-NORTHEAT WALL OF RM 12	192430-16948	5.7 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 12 -- BUBBLER1, C-NORTHEAT WALL OF RM 12	192430-16948	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 12 -- BUBBLER2, FCT - South Bldg Room #10	192430-41230	5.8 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NORTHEAT WALL OF RM 12 -- BUBBLER2, FCT - South Bldg Room #10	192430-41230	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 14 -- BUBBLER1, C-SW WALL OF RM 14	192432-16949	13 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 14 -- BUBBLER1, C-SW WALL OF RM 14	192432-16949	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 14 -- BUBBLER2, FCT - South Bldg Room #14	192432-41231	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 14 -- BUBBLER2, FCT - South Bldg Room #14	192432-41231	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 15 -- BUBBLER1, C-SW WALL OF RM 15	192434-16950	8 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 15 -- BUBBLER1, C-SW WALL OF RM 15	192434-16950	370 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 15 -- BUBBLER2, FCT - South Bldg Room #15	192434-41232	5.6 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 15 -- BUBBLER2, FCT - South Bldg Room #15	192434-41232	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 16 -- BUBBLER1, C-SW WALL OF RM 16	192436-16951	5.8 ppb

30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 16 -- BUBBLER1, C-SW WALL OF RM 16	192436-16951	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 16 -- BUBBLER2, FCT - South Bldg Room #16	192436-41233	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 16 -- BUBBLER2, FCT - South Bldg Room #16	192436-41233	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 17 -- BUBBLER1, C-SW WALL OF RM 17	192438-16952	9.2 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 17 -- BUBBLER1, C-SW WALL OF RM 17	192438-16952	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 17 -- BUBBLER2, FCT - South Bldg Room #17	192438-41234	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 17 -- BUBBLER2, FCT - South Bldg Room #17	192438-41234	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 30 2ND FL -- BUBBLER2, FCT - South Bldg Room #30	192440-41235	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 30 2ND FL -- BUBBLER2, FCT - South Bldg Room #30	192440-41235	<5 ppb
First Draw	DRINKING FOUNTAIN, 1 BUB. (INT.) - NE WALL OF RM 29 2ND FL -- BUBBLER1, C-NE WALL OF RM 29 2ND FL	192442-16954	5.3 ppb
30 Second Draw	DRINKING FOUNTAIN, 1 BUB. (INT.) - NE WALL OF RM 29 2ND FL -- BUBBLER1, C-NE WALL OF RM 29 2ND FL	192442-16954	<5 ppb
First Draw	DRINKING FOUNTAIN, 1 BUB. (INT.) - NE WALL OF RM 29 2ND FL -- BUBBLER2, FCT - South Bldg Room #29	192442-41236	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 1 BUB. (INT.) - NE WALL OF RM 29 2ND FL -- BUBBLER2, FCT - South Bldg Room #29	192442-41236	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 28 2ND FL -- BUBBLER1, C-NE WALL OF RM 28 2ND FL	192444-16955	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 28 2ND FL -- BUBBLER1, C-NE WALL OF RM 28 2ND FL	192444-16955	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 28 2ND FL -- BUBBLER2, FCT - South Bldg Room #28	192444-41237	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 28 2ND FL -- BUBBLER2, FCT - South Bldg Room #28	192444-41237	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 27 2ND FL -- BUBBLER1, C-NE WALL OF RM 27 2ND FL	192446-16956	8.7 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 27 2ND FL -- BUBBLER1, C-NE WALL OF RM 27 2ND FL	192446-16956	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 27 2ND FL -- BUBBLER2, FCT - South Bldg Room #27	192446-41238	7.7 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 27 2ND FL -- BUBBLER2, FCT - South Bldg Room #27	192446-41238	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 26 2ND FL -- BUBBLER1, C-NE WALL OF RM 26 2ND FL	192448-16957	5.2 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 26 2ND FL -- BUBBLER1, C-NE WALL OF RM 26 2ND FL	192448-16957	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 26 2ND FL -- BUBBLER2, FCT - South Bldg #26	192448-41239	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 26 2ND FL -- BUBBLER2, FCT - South Bldg #26	192448-41239	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 21 2ND FL -- BUBBLER1, C-SW WALL OF RM 21 2ND FL	192450-16958	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 21 2ND FL -- BUBBLER1, C-SW WALL OF RM 21 2ND FL	192450-16958	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 21 2ND FL -- BUBBLER2, FCT - South Bldg Room #21	192450-41240	5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 21 2ND FL -- BUBBLER2, FCT - South Bldg Room #21	192450-41240	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 22 2ND FL -- BUBBLER1, C-SW WALL OF RM 22 2ND FL	192452-16959	12 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 22 2ND FL -- BUBBLER1, C-SW WALL OF RM 22 2ND FL	192452-16959	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 22 2ND FL -- BUBBLER2, FCT - South Bldg Room #22	192452-41241	6.8 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 22 2ND FL -- BUBBLER2, FCT - South Bldg Room #22	192452-41241	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 23 2ND FL -- BUBBLER1, C-SW WALL OF RM 23 2ND FL	192454-16960	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 23 2ND FL -- BUBBLER1, C-SW WALL OF RM 23 2ND FL	192454-16960	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 23 2ND FL -- BUBBLER2, FCT - South Bldg Room #23	192454-41242	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 23 2ND FL -- BUBBLER2, FCT - South Bldg Room #23	192454-41242	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 24 2ND FL -- BUBBLER1, C-SW WALL OF RM 24 2ND FL	192456-16961	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 24 2ND FL -- BUBBLER1, C-SW WALL OF RM 24 2ND FL	192456-16961	8 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 24 2ND FL -- BUBBLER2, FCT - South Bldg Room #24	192456-41243	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 24 2ND FL -- BUBBLER2, FCT - South Bldg Room #24	192456-41243	7.3 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 25 2ND FL -- BUBBLER1, C-SW WALL OF RM 25 2ND FL	192458-16962	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 25 2ND FL -- BUBBLER1, C-SW WALL OF RM 25 2ND FL	192458-16962	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 25 2ND FL -- BUBBLER2, FCT - South Bldg Room #24	192458-41244	8.2 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 25 2ND FL -- BUBBLER2, FCT - South Bldg Room #24	192458-41244	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 18 2ND FL -- BUBBLER1, C-NW WALL OF RM 18 2ND FL	192460-16963	7 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 18 2ND FL -- BUBBLER1, C-NW WALL OF RM 18 2ND FL	192460-16963	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 18 2ND FL -- BUBBLER2, FCT - Admin Bldg Room #18	192460-41245	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 18 2ND FL -- BUBBLER2, FCT - Admin Bldg Room #18	192460-41245	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 19 2ND FL -- BUBBLER1, C-NW WALL OF RM 19 2ND FL	192462-16964	5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 19 2ND FL -- BUBBLER1, C-NW WALL OF RM 19 2ND FL	192462-16964	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 19 2ND FL -- BUBBLER2, FCT - Admin Bldg Room #19	192462-41246	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 19 2ND FL -- BUBBLER2, FCT - Admin Bldg Room #19	192462-41246	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 20 2ND FL -- BUBBLER1, C-NW WALL OF RM 20 2ND FL	192464-16965	6.6 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 20 2ND FL -- BUBBLER1, C-NW WALL OF RM 20 2ND FL	192464-16965	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 20 2ND FL -- BUBBLER2, FCT - Admin Bldg Room #20	192464-41247	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 20 2ND FL -- BUBBLER2, FCT - Admin Bldg Room #20	192464-41247	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER1, L-NE EXTERIOR WALL OF MAIN BL	192466-16966	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER1, L-NE EXTERIOR WALL OF MAIN BL	192466-16966	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER2, R-NE EXTERIOR WALL OF MAIN BL	192466-16967	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER2, R-NE EXTERIOR WALL OF MAIN BL	192466-16967	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER1, L-NE EXTERIOR WALL OF MAIN BL	192469-16968	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER1, L-NE EXTERIOR WALL OF MAIN BL	192469-16968	<5 ppb
First Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER2, R-NE EXTERIOR WALL OF MAIN BL	192469-16969	<5 ppb
30 Second Draw	DRINKING FOUNTAIN, 2 BUB. (EXT.) - NE EXT WALL OF MN BLDG -- BUBBLER2, R-NE EXTERIOR WALL OF MAIN BL	192469-16969	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 32 -- BUBBLER1, C-SW WALL OF RM 32	192472-16970	29 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 32 -- BUBBLER1, C-SW WALL OF RM 32	192472-16970	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 32 -- BUBBLER2, FCT - Bldg 1 Room #32	192472-41248	14 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 32 -- BUBBLER2, FCT - Bldg 1 Room #32	192472-41248	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 34 -- BUBBLER1, C-SW WALL OF RM 34	192474-16972	15 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 34 -- BUBBLER1, C-SW WALL OF RM 34	192474-16972	5.3 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 34 -- BUBBLER2, FCT - Bldg 1 Room #34	192474-41249	28 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 34 -- BUBBLER2, FCT - Bldg 1 Room #34	192474-41249	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 36 -- BUBBLER1, C-NW WALL OF RM 36	192476-16971	17 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 36 -- BUBBLER1, C-NW WALL OF RM 36	192476-16971	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 36 -- BUBBLER2, FCT - Bldg 1 Room #36	192476-41250	24 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 36 -- BUBBLER2, FCT - Bldg 1 Room #36	192476-41250	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 37 -- BUBBLER1, C-SE WALL OF RM 37	192478-16973	13 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 37 -- BUBBLER1, C-SE WALL OF RM 37	192478-16973	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 37 -- BUBBLER2, FCT - Bldg 1 Room #37	192478-41251	14 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 37 -- BUBBLER2, FCT - Bldg 1 Room #37	192478-41251	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 35 -- BUBBLER1, C-NE WALL OF RM 35	192480-16974	23 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 35 -- BUBBLER1, C-NE WALL OF RM 35	192480-16974	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 35 -- BUBBLER2, FCT - Bldg 1 Room #35	192480-41252	12 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 35 -- BUBBLER2, FCT - Bldg 1 Room #35	192480-41252	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 33 -- BUBBLER1, C-SW WALL OF RM 33	192482-16975	19 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 33 -- BUBBLER1, C-SW WALL OF RM 33	192482-16975	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 33 -- BUBBLER2, FCT - Bldg 1 Room #33	192482-41253	8.5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 33 -- BUBBLER2, FCT - Bldg 1 Room #33	192482-41253	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 31 -- BUBBLER1, C-NE WALL OF RM 31	192484-16976	38 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 31 -- BUBBLER1, C-NE WALL OF RM 31	192484-16976	5.6 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 31 -- BUBBLER2, FCT - Bldg 1 Room #31	192484-41254	20 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 31 -- BUBBLER2, FCT - Bldg 1 Room #31	192484-41254	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 38 -- BUBBLER1, C-NW WALL OF RM 38	192486-16977	21 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 38 -- BUBBLER1, C-NW WALL OF RM 38	192486-16977	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 38 -- BUBBLER2, FCT - Bldg 1 Room #38	192486-41255	13 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 38 -- BUBBLER2, FCT - Bldg 1 Room #38	192486-41255	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 40 -- BUBBLER1, C-SW WALL OF RM 40	192488-16978	16 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 40 -- BUBBLER1, C-SW WALL OF RM 40	192488-16978	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 40 -- BUBBLER2, FCT - Bldg 1 Room #40	192488-41256	11 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 40 -- BUBBLER2, FCT - Bldg 1 Room #40	192488-41256	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 40 -- BUBBLER1, C-NW WALL OF RM 40	192490-16979	10 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 40 -- BUBBLER1, C-NW WALL OF RM 40	192490-16979	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 40 -- BUBBLER2, FCT - Bldg 1 Room #40	192490-41257	9.1 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 40 -- BUBBLER2, FCT - Bldg 1 Room #40	192490-41257	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 44 -- BUBBLER1, C-SW WALL OF RM 44	192492-16980	6.8 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 44 -- BUBBLER1, C-SW WALL OF RM 44	192492-16980	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 44 -- BUBBLER2, FCT - Bldg 1 Room #44	192492-41258	13 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 44 -- BUBBLER2, FCT - Bldg 1 Room #44	192492-41258	<5 ppb
First Draw	SINK, 3 BUB. (EXT.) - W EXTERIOR WALL OF BLDG ON PLAYGROUND -- BUBBLER1, L-W EXT WALL OF BLDG ON PLA	192494-16981	6.6 ppb
30 Second Draw	SINK, 3 BUB. (EXT.) - W EXTERIOR WALL OF BLDG ON PLAYGROUND -- BUBBLER1, L-W EXT WALL OF BLDG ON PLA	192494-16981	<5 ppb
First Draw	SINK, 3 BUB. (EXT.) - W EXTERIOR WALL OF BLDG ON PLAYGROUND -- BUBBLER2, C-W EXT WALL OF BLDG ON PLA	192494-16982	<5 ppb
30 Second Draw	SINK, 3 BUB. (EXT.) - W EXTERIOR WALL OF BLDG ON PLAYGROUND -- BUBBLER2, C-W EXT WALL OF BLDG ON PLA	192494-16982	<5 ppb
First Draw	SINK, 3 BUB. (EXT.) - W EXTERIOR WALL OF BLDG ON PLAYGROUND -- BUBBLER3, R-W EXT WALL OF BLDG ON PLA	192494-16983	<5 ppb
30 Second Draw	SINK, 3 BUB. (EXT.) - W EXTERIOR WALL OF BLDG ON PLAYGROUND -- BUBBLER3, R-W EXT WALL OF BLDG ON PLA	192494-16983	<5 ppb
First Draw	DRINKING FOUNTAIN, 1 BUB. W/CHILLER (INT.) - N INTERIOR WALL OF CAFÉ -- BUBBLER1, C-N INTERIOR WALL	192504-16988	9.3 ppb
30 Second Draw	DRINKING FOUNTAIN, 1 BUB. W/CHILLER (INT.) - N INTERIOR WALL OF CAFÉ -- BUBBLER1, C-N INTERIOR WALL	192504-16988	9.9 ppb
First Draw	SINK, 1 BUB. (INT.) - N END WALL OF RM 46 -- BUBBLER1, C-N END WALL OF RM 46	192506-16989	16 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - N END WALL OF RM 46 -- BUBBLER1, C-N END WALL OF RM 46	192506-16989	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - N END WALL OF RM 46 -- BUBBLER2, FCT - Bldg 2 Room #46	192506-41259	15 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - N END WALL OF RM 46 -- BUBBLER2, FCT - Bldg 2 Room #46	192506-41259	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 45 2ND FL -- BUBBLER1, C-SE WALL OF RM 45 2ND FL	192508-16990	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 45 2ND FL -- BUBBLER1, C-SE WALL OF RM 45 2ND FL	192508-16990	14 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 45 2ND FL -- BUBBLER2, FCT - Bldg 1 Room #45	192508-41260	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 45 2ND FL -- BUBBLER2, FCT - Bldg 1 Room #45	192508-41260	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 43 2ND FL -- BUBBLER1, C-NE WALL OF RM 43 2ND FL	192510-16991	14 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 43 2ND FL -- BUBBLER1, C-NE WALL OF RM 43 2ND FL	192510-16991	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 43 2ND FL -- BUBBLER2, FCT - Bldg 1 Room #43	192510-41261	13 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 43 2ND FL -- BUBBLER2, FCT - Bldg 1 Room #43	192510-41261	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER1, C-SE WALL OF RM 41 2ND FL	192512-16992	28 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER1, C-SE WALL OF RM 41 2ND FL	192512-16992	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER2, FCT - Bldg 1 Room #41	192512-41262	26 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER2, FCT - Bldg 1 Room #41	192512-41262	6.6 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 39 2ND FL -- BUBBLER1, C-NE WALL OF RM 39 2ND FL	192514-16993	24 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 39 2ND FL -- BUBBLER1, C-NE WALL OF RM 39 2ND FL	192514-16993	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 39 2ND FL -- BUBBLER2, FCT - NE WALL OF RM 39 2ND FL	192514-41263	17 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 39 2ND FL -- BUBBLER2, FCT - NE WALL OF RM 39 2ND FL	192514-41263	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 47 -- BUBBLER1, C-NE WALL OF RM 47	192516-16994	6.4 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 47 -- BUBBLER1, C-NE WALL OF RM 47	192516-16994	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 47 -- BUBBLER2, FCT - Bldg 2 Room #47	192516-41264	11 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 47 -- BUBBLER2, FCT - Bldg 2 Room #47	192516-41264	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER1, C-SE WALL OF RM 41 2ND FL	192518-16995	8.3 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER1, C-SE WALL OF RM 41 2ND FL	192518-16995	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER2, FCT - Bldg 2 Room #48	192518-41265	7.2 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 41 2ND FL -- BUBBLER2, FCT - Bldg 2 Room #48	192518-41265	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 49 -- BUBBLER1, C-SW WALL OF RM 49	192520-16996	13 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 49 -- BUBBLER1, C-SW WALL OF RM 49	192520-16996	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 49 -- BUBBLER2, FCT - Bldg 2 Room #49	192520-41266	9.4 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 49 -- BUBBLER2, FCT - Bldg 2 Room #49	192520-41266	<5 ppb
First Draw	SINK, 2 BUB. (EXT.) - S EXTERIOR WALL OF RM 49 -- BUBBLER1, L-S EXTERIOR WALL OF RM 49	192522-16997	16 ppb
30 Second Draw	SINK, 2 BUB. (EXT.) - S EXTERIOR WALL OF RM 49 -- BUBBLER1, L-S EXTERIOR WALL OF RM 49	192522-16997	<5 ppb
First Draw	SINK, 2 BUB. (EXT.) - S EXTERIOR WALL OF RM 49 -- BUBBLER2, R-S EXTERIOR WALL OF RM 49	192522-16998	31 ppb
30 Second Draw	SINK, 2 BUB. (EXT.) - S EXTERIOR WALL OF RM 49 -- BUBBLER2, R-S EXTERIOR WALL OF RM 49	192522-16998	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 50 -- BUBBLER1, C-SE WALL OF RM 50	192525-16999	14 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 50 -- BUBBLER1, C-SE WALL OF RM 50	192525-16999	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 50 -- BUBBLER2, FCT - Bldg 2 Room #50	192525-41267	12 ppb

30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 50 -- BUBBLER2, FCT - Bldg 2 Room #50	192525-41267	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 51 -- BUBBLER1, C-NW SIDE OF RM 51	192527-17000	9.1 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 51 -- BUBBLER1, C-NW SIDE OF RM 51	192527-17000	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 51 -- BUBBLER2, FCT - Bldg 2 room #51	192527-41268	7.1 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 51 -- BUBBLER2, FCT - Bldg 2 room #51	192527-41268	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 52 -- BUBBLER1, C-NW SIDE OF RM 52	192529-17001	13 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 52 -- BUBBLER1, C-NW SIDE OF RM 52	192529-17001	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 52 -- BUBBLER2, FCT - Bldg 2 Room #52	192529-41269	14 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 52 -- BUBBLER2, FCT - Bldg 2 Room #52	192529-41269	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 53 -- BUBBLER1, C-NW SIDE OF RM 53	192531-17002	19 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 53 -- BUBBLER1, C-NW SIDE OF RM 53	192531-17002	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 53 -- BUBBLER2, FCT - Bldg 2 Room 353	192531-41270	17 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 53 -- BUBBLER2, FCT - Bldg 2 Room 353	192531-41270	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 54 -- BUBBLER1, C-NE WALL OF RM 54	192533-17003	9.5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 54 -- BUBBLER1, C-NE WALL OF RM 54	192533-17003	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 54 -- BUBBLER2, FCT - Bldg 2 Room #54	192533-41271	5.2 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 54 -- BUBBLER2, FCT - Bldg 2 Room #54	192533-41271	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 55 -- BUBBLER1, C-NE WALL OF RM 55	192535-17004	8.1 ppb

30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 55 -- BUBBLER1, C-NE WALL OF RM 55	192535-17004	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 55 -- BUBBLER2, FCT - Bldg 2 Room #55	192535-41272	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 55 -- BUBBLER2, FCT - Bldg 2 Room #55	192535-41272	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 56 -- BUBBLER1, C-SE WALL OF RM 56	192537-17005	7.5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 56 -- BUBBLER1, C-SE WALL OF RM 56	192537-17005	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 56 -- BUBBLER2, FCT - Bldg 2 Room #56 Bldg 2 Rm # 56	192537-41273	15 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 56 -- BUBBLER2, FCT - Bldg 2 Room #56 Bldg 2 Rm # 56	192537-41273	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 57 -- BUBBLER1, C-SW WALL OF RM 57	192539-17006	17 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 57 -- BUBBLER1, C-SW WALL OF RM 57	192539-17006	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 57 -- BUBBLER2, FCT - Bldg 2 Room #57	192539-41274	6.3 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 57 -- BUBBLER2, FCT - Bldg 2 Room #57	192539-41274	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 58 -- BUBBLER1, C-SE WALL OF RM 58	192541-17007	15 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 58 -- BUBBLER1, C-SE WALL OF RM 58	192541-17007	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 58 -- BUBBLER2, FCT - Bldg 2 Room #58	192541-41275	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 58 -- BUBBLER2, FCT - Bldg 2 Room #58	192541-41275	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 59 -- BUBBLER1, C-NW SIDE OF RM 59	192543-17008	11 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 59 -- BUBBLER1, C-NW SIDE OF RM 59	192543-17008	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 59 -- BUBBLER2, FCT - Bldg 2 Room #59	192543-41276	20 ppb

30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 59 -- BUBBLER2, FCT - Bldg 2 Room #59	192543-41276	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 60 -- BUBBLER1, C-NW SIDE OF RM 60	192545-17009	60 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 60 -- BUBBLER1, C-NW SIDE OF RM 60	192545-17009	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 60 -- BUBBLER2, FCT - Bldg 2 Room #60	192545-41277	32 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW SIDE OF RM 60 -- BUBBLER2, FCT - Bldg 2 Room #60	192545-41277	<5 ppb
First Draw	SINK, 3 BUB. (INT.) - SW EXT WALL BTWN BOY & GIRLS RESTRM -- BUBBLER1, L-SW EXT WALL BTWN BOY & GIRL	192547-17010	<5 ppb
30 Second Draw	SINK, 3 BUB. (INT.) - SW EXT WALL BTWN BOY & GIRLS RESTRM -- BUBBLER1, L-SW EXT WALL BTWN BOY & GIRL	192547-17010	5.1 ppb
First Draw	SINK, 3 BUB. (INT.) - SW EXT WALL BTWN BOY & GIRLS RESTRM -- BUBBLER2, C-SW EXT WALL BTWN BOY & GIRL	192547-17011	<5 ppb
30 Second Draw	SINK, 3 BUB. (INT.) - SW EXT WALL BTWN BOY & GIRLS RESTRM -- BUBBLER2, C-SW EXT WALL BTWN BOY & GIRL	192547-17011	<5 ppb
First Draw	SINK, 3 BUB. (INT.) - SW EXT WALL BTWN BOY & GIRLS RESTRM -- BUBBLER3, R-SW EXT WALL BTWN BOY & GIRL	192547-17012	<5 ppb
30 Second Draw	SINK, 3 BUB. (INT.) - SW EXT WALL BTWN BOY & GIRLS RESTRM -- BUBBLER3, R-SW EXT WALL BTWN BOY & GIRL	192547-17012	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 67 BUNGALOW -- BUBBLER1, C-NW WALL OF RM 67 BUNGALOW	192551-17013	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 67 BUNGALOW -- BUBBLER1, C-NW WALL OF RM 67 BUNGALOW	192551-17013	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 67 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #67	192551-41278	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 67 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #67	192551-41278	<5 ppb

First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 68 BUNGALOW -- BUBBLER1, C-NW WALL OF RM 68 BUNGALOW	192553-17014	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 68 BUNGALOW -- BUBBLER1, C-NW WALL OF RM 68 BUNGALOW	192553-17014	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 68 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #68	192553-41279	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NW WALL OF RM 68 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #68	192553-41279	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 65 BUNGALOW -- BUBBLER1, C-SE WALL OF RM 65 BUNGALOW	192555-17015	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 65 BUNGALOW -- BUBBLER1, C-SE WALL OF RM 65 BUNGALOW	192555-17015	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 65 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #65	192555-41280	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SE WALL OF RM 65 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #65	192555-41280	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 65 BUNGALOW -- BUBBLER1, C-SW WALL OF RM 65 BUNGALOW	192557-17016	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 65 BUNGALOW -- BUBBLER1, C-SW WALL OF RM 65 BUNGALOW	192557-17016	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 65 BUNGALOW -- BUBBLER2, FCT - Bubgalow Rm #66	192557-41281	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - SW WALL OF RM 65 BUNGALOW -- BUBBLER2, FCT - Bubgalow Rm #66	192557-41281	<5 ppb
First Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 63 BUNGALOW -- BUBBLER1, C-NE WALL OF RM 63 BUNGALOW	192559-17017	<5 ppb
30 Second Draw	SINK, 1 BUB. (INT.) - NE WALL OF RM 63 BUNGALOW -- BUBBLER1, C-NE WALL OF RM 63 BUNGALOW	192559-17017	<5 ppb

<b>First Draw</b>	SINK, 1 BUB. (INT.) - NE WALL OF RM 63 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #63	192559-41282	<5 ppb
<b>30 Second Draw</b>	SINK, 1 BUB. (INT.) - NE WALL OF RM 63 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #63	192559-41282	<5 ppb
<b>First Draw</b>	SINK, 1 BUB. (INT.) - NW WALL OF RM 64 BUNGALOW -- BUBBLER1, C-NW WALL OF RM 64 BUNGALOW	192561-17018	<5 ppb
<b>30 Second Draw</b>	SINK, 1 BUB. (INT.) - NW WALL OF RM 64 BUNGALOW -- BUBBLER1, C-NW WALL OF RM 64 BUNGALOW	192561-17018	<5 ppb
<b>First Draw</b>	SINK, 1 BUB. (INT.) - NW WALL OF RM 64 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #64	192561-41283	<5 ppb
<b>30 Second Draw</b>	SINK, 1 BUB. (INT.) - NW WALL OF RM 64 BUNGALOW -- BUBBLER2, FCT - Bungalow Rm #64	192561-41283	<5 ppb

*Drinking water fixtures that exceed the action level of 15 ppb on the first draw will be retested after flushing for 30 seconds. If the results are still above 15 ppb the fixture will be shut off until corrective actions to reduce lead levels have been implemented.*

[Click here to Print this Page](#)